



**NOTES:**

1. FULL LENGTH INSULATING SLEEVES REQUIRED AT ALL THRU-FLANGE BOLTS OR STUDS. HALF LENGTH SLEEVES REQUIRED AT THREADED BOLT HOLES AT VALVE BONNET AND BASE.
2. NO TEST STATION REQUIRED ON BLOW-OFF INSULATORS.

| REVISION | BY | APPR | DATE |
|----------|----|------|------|
|          |    |      |      |
|          |    |      |      |
|          |    |      |      |
|          |    |      |      |
|          |    |      |      |

**ELSINORE VALLEY**  
MUNICIPAL WATER DISTRICT

*Parag Kalaria*  
06/22/2023  
PARAG KALARIA R.C.E. 83927 DATE

**BURIED INSULATING FLANGE AT VALVE**

STD. DWG. NO.  
**CP-2**