



NOTES:

1. TOP OF TEST BOX SHALL BE SET FLUSH WITH GRADE.
2. ALL WIRES SHALL HAVE 18" MIN. SLACK IN BOX.
3. BOTTOM OF TEST BOX SHALL BE NATIVE SOIL. DO NOT PLACE ROCK, GRAVEL, OR SAND IN TEST BOX.
4. TEST BOX SHALL BE LOCATED BEHIND SIDEWALK. IF NO SIDEWALK EXISTS, THEN INSTALL BEHIND THE CURB..
5. PROVIDE 24"X24"X4" THICK REINFORCED SQUARE CONCRETE PAD AROUND TEST BOXES AT UNPAVED SITES.
6. BRASS TAGS SHALL BE STAMPED WITH 1/4" HIGH CHARACTERS AND SHALL IDENTIFY PIPE SIZE, MATERIAL, SERVICE AND DIRECTION.

REVISION	BY	APPR	DATE

EL SINORE VALLEY
MUNICIPAL WATER DISTRICT

06/22/2023
PARAG KALARIA R.C.E. 83927 DATE

**INSULATING FLANGE
TEST STATION**

STD. DWG. NO.
CP-4