



**NOTES:**

1. PLACE AT GRADE CTS AT ONE OF THE THREE LOCATIONS SHOWN PER DRAWINGS OR PER DIRECTION FROM DISTRICT'S REPRESENTATIVE. FOR ROAD WITHOUT CURB PLACE AT-GRADE CTS BEYOND PAVEMENT OUT OF TRAFFIC LANES BUT WITHIN EASEMENT.
2. USE POST-MOUNTED CTS IN UNDEVELOPED SITES. PLACE DIRECTLY OVER PIPE WHERE POSSIBLE, OR AS DIRECTED BY DISTRICT'S REPRESENTATIVE.
3. PROVIDE SAND BEDDING AND BACKFILL IN WIRE TRENCHES. SEE STD SPEC.
4. WARNING TAPE SHALL BE 6" WIDE, 4 MIL. THICK INERT PLASTIC WARNING TAPE PRINTED WITH "CAUTION: CATHODIC PROTECTION CABLE BELOW"
5. USE SIMILAR MOUNTING FOR MULTI-WIRE CTS.

REVISION	BY	APPR	DATE

**EL SINORE VALLEY**  
MUNICIPAL WATER DISTRICT

06/22/2023  
PARAG KALARIA R.C.E. 83927 DATE

**2-WIRE CATHODIC TEST STATION  
(CTS)**

STD. DWG. NO.  
**CP-7**