


RECYCLED WATER GENERAL NOTES

1. Five (5) days prior to commencement of any excavation of on-site improvements, the contractor shall notify the Elsinore Valley Municipal Water District Engineering and Inspection Department at (951) 674-3146 x 8402.
2. All work shall be done in accordance with the Elsinore Valley Municipal Water District (EVMWD) "Rules and Regulations for Recycled Water Use and Distribution within the Elsinore Valley Municipal Water District", and the State Water Resources Control Board - Division of Drinking Water (DDW) requirements.
3. Cross connection between recycled water lines and potable water lines is strictly prohibited.
4. No substitution of pipe materials will be allowed without prior approval by the EVMWD and DDW.
5. All below grade recycled water pipe shall be color code purple pantone #522 or distinctively sleeved in purple recycled water protective wrapping or in purple tape fixed to top of pipe and stenciled with "Caution recycled water - DO NOT DRINK". Orient the stenciling to the top of the trench for laterals. Install purple metallic tape over the recycled water mains per the recycled water system standard design requirements in the EVMWD standard specifications and drawings.
6. All above ground recycled water facilities shall be purple colored pantone #512 and marked to differentiate recycled water facilities from potable water or wastewater facilities per American Water Works Association (AWWA) guidelines and section 116815 of the California Health and Safety Code.
7. Provide a minimum cover of all pipes in accordance with EVMWD standard specifications and drawings per the standard design requirements for recycled water pipelines.
8. Maintain separation between potable water, recycled water, and/or sewer pipelines according to the EVMWD standard drawings and CDPH guidance memo no. 2003-02 latest revision.
9. All public and private potable water mains including fire mains, services and any water wells and water courses within the recycled water project shall be shown on the plans.
10. Tag all valves and other below grade facilities within boxes with permanent recycled water labels that identify the facility as "Recycled Water - DO NOT DRINK NO BEBER". Attach the label with either stainless steel wire or self-locking plastic ties.
11. Blowoff assemblies for recycled water shall be in accordance with EVMWD standard drawing RW-1.
12. All public facilities such as comfort stations, drinking fountains, outdoor eating areas, etc. shall be protected from spray and or misting by recycled water.
13. No ponding, run-off, misting, or over spray is permitted. Relocate or adjust all irrigation heads to prevent over spraying onto sidewalks, streets, private lots, and areas not approved for recycled water use.

REVISION	BY	APPR	DATE		STD. DWG. NO.	
				 <p>ELSINORE VALLEY MUNICIPAL WATER DISTRICT</p> <p><i>Parag Kalaria</i> 06/22/2023 PARAG KALARIA R.C.E. 83927 DATE</p>	<p>RECYCLED WATER GENERAL NOTES</p>	<p>GN-5</p>