



NOTES:

1. RESTRAINED JOINTS ARE REQUIRED.
2. BLOW-OFF (WHARF HEAD BODY) TO BE PAINTED PURPLE DESCRIPTION

| ITEM | EACH | DESCRIPTION | SPEC. | REMARKS |
|------|------|--|-----------------------------------|--|
| ① | 1 | STD. 6" TEE BRANCH | D.I. FLG ON 6" BRANCH | |
| ② | 1 | 6" GATE VALVE | SEE W-13 AND W-14 | RESILIENT WEDGE, FLGxFLG |
| ③ | 1 | 8" VALVE WELL AND CAP | SEE W-13 (LABELED RECYCLED WATER) | PAINTED PURPLE |
| ④ | 1 | 6" PIPE BLOWOFF RUN | STD. DWG. W-7 | RESTRAINED JOINT |
| ⑤ | 1 | 6" STD. FIRE HYDRANT BURY 6" SPOOL FL x FL (DI) | | 6 HOLE FLG x FLG (VARIABLE HEIGHT) |
| ⑥ | 1 | 6" GROOVED BREAK OFF SPOOL | 6", 6 HOLE, FLxFL, SEE W-7 | SPOOL ABOVE SURFACE, PAINTED, NUTS ON TOP OF FLANGE, DAMAGE 2 OPPOSITE FACING THREADED ENDS TO ENSURE INABILITY OF REMOVAL |
| ⑦ | 1 | 6"x4" COMPANION FLANGE | 6", 6 HOLE, FLxFL | BLACK IRON COMPANION FLANGE, PAINTED |
| ⑧ | 1 | 4" PIPE WITH INTERIOR EPOXY LINED COATED | GALVANIZED, 4" M.I.P. x M.I.P. | PAINTED PURPLE |
| ⑨ | 1 | 4" ANGLE FIRE PLUG VALVE | 4" x 2 1/2" | PAINTED PURPLE (WHARF HEAD) |
| ⑩ | - | VALVE SUPPORT BLOCK | STD. DWG. W-15 | |
| ⑪ | 1 | 560 C3250 CONCRETE PAD | 4'x4'x4"DEEP | |
| ⑫ | 1 | 6" DIA. 90° BASE ELBOW, SHORT RADIUS | FLxMJ OR FLxFL | VARIABLE HEIGHT. |
| ⑬ | 1 | TRACER BOX | SEE APPROVED MATERIALS LIST | |

| REVISION | BY | APPR | DATE |
|----------|----|------|------|
| | | | |
| | | | |
| | | | |
| | | | |

PARAG KALARIA R.C.E. 83927 DATE 06/22/2023

RECYCLED WATER BLOW-OFF ASSEMBLY

STD. DWG. NO.
RW-1