



**SECTION A-A**

**NOTE:**

1. THIS STD. DWG. TO BE USED ONLY WITH WRITTEN APPROVAL FROM EVMWD ENGINEERING DEPARTMENT.
2. EXCEPT AS INDICATED HEREON OR ON THE PROJECT PLANS, MANHOLES SHALL CONFORM TO STD. DWG. S-8
3. MANHOLES AT INTERSECTIONS SHALL HAVE STUB OUTS IN THE OTHER TWO DIRECTIONS WITH RESPECT TO THE INLET AND OUTLET. SEE SECTION 2.04B OF THE STANDARD DESIGN REQUIREMENTS.
4. SEE SECTION 2.04B OF THE STANDARD DESIGN REQUIREMENTS FOR INLET AND OUTLET PIPE OF DIFFERENT SIZES.
5. DROP ACROSS MANHOLE SHALL BE 0.1' MIN. SEE STANDARD DESIGN REQUIREMENTS SECTION 2.04B-5B FOR SPECIFIC DIRECTIONS.

REVISION	BY	APPR	DATE

PARAG KALARIA R.C.E. 83927 DATE 06/22/2023

**PRECAST CONCRETE  
DROP MANHOLE**

STD. DWG. NO.  
**S-8**