

HAND RAIL HEIGHT, SIZE, & CONSTRUCTION TO MEET ALL APPLICABLE SAFETY & BUILDING CODES AND SHALL BE RATED FOR FALL PROTECTION

TOP OF KNUCKLE

TANK ACCESS HATCH

10" CLR

5'-0" MIN.

10" CLR

32" WIDE GATE


2'-6"

5'-8"

ANTI-SKID COATING WITHIN FENCE AREA

NOTE:
 HANDRAIL AGAINST TANK FROM TOP OF PLATFORM TO 1 FOOT BELOW BOTTOM OF KNUCKLE.
 HANDRAIL TO EXTEND MIN. 1/2" FROM SHELL AT ALL LOCATIONS.

REVISION	BY	APPR	DATE



ELSINORE VALLEY
 MUNICIPAL WATER DISTRICT

06/22/2023
 PARAG KALARIA R.C.E. 83927 DATE

WELDED STEEL RESERVOIR STAIRWAY AND ROOF HANDRAIL

STD. DWG. NO.
T-3