

- . REFER TO NOTES ON STANDARD DRAWING W-21A.
- 2. REFER TO STANDARD DRAWING W-21B FOR IDENTIFICATION OF MATERIALS AND OPENINGS.
- 3. INSTALL WARNING/IDENTIFICATION TAPE AS SHOWN ON W-21A.
- 4. THE FEED PIPE DIAMETER SHALL BE A MINIMUM (6"), OR LARGER AS REQUIRED, TO MATCH BACKFLOW PREVENTER. THE SUPPLY LINE MAY BE REDUCED FOR INSTALLATIONS REQUIRING PIPE OF LESS THAN 6" IN DIAMETER.
- 5. PAINTING SHALL BE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS, COLOR SHALL BE PURPLE PER APPROVED MATERIALS LIST.
- 6. TESTING SHALL BE CONDUCTED AS CALLED FOR IN THE STANDARD SPECIFICATIONS PRIOR TO ACCEPTANCE BY THE DISTRICT.
- 7. MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST.
- 8. IDENTIFICATION PLATE AND TEST VALVES ON THE BACKFLOW ASSEMBLY SHALL NOT BE PAINTED.

REVISION	BY	APPR	DATE	.	
				🌉 ELSINORE	TEMPORARY POTABLE WATER
					TO RECYCLED WATER
				MUNICIPAL WATER DISTRICT PP Balana - 06/22/2023	INTER-CONNECTION
				PARAG KALARIA R.C.E. 83927 DATE	

STD. DWG. NO.

W-8