



FIRE HYDRANT PRESSURE TEST APPLICATION FORM
 (The average processing time is between 14 to 20 business days from the date of a complete submittal)

APPLICANT INFORMATION

Date of Request:	
Customer Name:	
Contact Person Name:	
Mailing Address:	
City, State, Zip	
Contact Phone:	
Contact Person Email Address:	

PROJECT INFORMATION

Assessor Parcel Number(s)	
Project Address:	
Project Type:	

TEST PARAMETERS:

Fire Agency Conditions: Gallons Per Minute (GPM):	
---	--

FOR EVMWD USE ONLY:

Date Received:			
Delivered to Ops:			
Received from Ops:		Date Due from Ops:	
Due to Applicant:			

Please submit completed application form and \$125.00 payment to the Engineering Department
 Make checks payable to EVMWD or via Credit Card [Fire Flow Credit Card Form Link](#)
 31315 Chaney Street, Lake Elsinore, CA 92530-3000
 (951) 674-3146 Ext 6705, engservices@evmwd.net

Residential Single Lot Fire Agency Conditions Example



Riverside County Fire Department – Office of the Fire Marshal

Riverside Office 2300 Market St, Ste 150, Riverside, CA 92501 Ph. (951) 955-4777 Fax (951) 955-4886
Palm Desert Office 77-933 Las Montañas Rd, # 201 Palm Desert, CA 92211-4131 Ph (760) 863-8886 Fax (760) 863-7072

HYDRANT FIRE FLOW VERIFICATION REQUEST

Permit # BR51901411
APN # 291-200-014
Address: 27164 Swift St
Menifee, CA 92584

Office Use Only

RIVERSIDE COUNTY FIRE DEPARTMENT HAS CONDUCTED A PRELIMINARY REVIEW FOR PERMIT APPLICATION PURPOSES ONLY AND NOT FOR PERMIT ISSUANCE. ANY INFORMATION PROVIDED IS SUBJECT TO CHANGE AND IS VALID FOR 180 DAYS.

DATE: 11/18/19 BY: [Signature]

RVCID Wet Stamp Only

Please provide the permit number for the building/installation/site preparation issued by the Building and Safety Department on all plans, documents, and correspondence. Without the permit number, we cannot process the permit. The following shall be obtained from the local water purveyor and submitted to the Riverside County Fire Department for review and approval prior to any releases.

The following information shall be included on all letter(s) and map(s):

1. A map and Assessor's Parcel Number (APN) showing the location of the fire hydrant and access roadway(s) to the property.
2. Written verification from the local water district shall be required indicating the ability to provide the following:
 - a. An approved standard fire hydrant (6"x4"x2½") shall be located within 600 feet from the hydrant to the furthest portion of the building as measured along the exterior ground floor walls.
 - b. The minimum fire flow shall be 875 gpm at 20 psi residual pressure for a ½ hour duration.
 - c. Water district must also indicate the size of the water main serving the fire hydrant.

Construction Type VB Square Feet 2071 Fire Sprinklered Non-Fire Sprinklered

At the applicant's request, this form is being provided prior to the site plan/architectural review. Therefore, fire flow requirements may not be accurate, and an additional fire flow letter may be required.

Applicant's Signature

Only **original** documents will be accepted. Copies and faxes of the letter and map will not be accepted.

*Valid for 1 year



Standard Hydrant
(Wet Barrel)



Super Hydrant
(Wet Barrel)



Super Hydrant
(Dry Barrel)



Wharf Hydrant
(Wet Barrel)

Commercial Lots Fire Agency Conditions Example



Riverside County Fire Department – Office of the Fire Marshal

Riverside Office 2300 Market St. Ste 150, Riverside, CA 92501 Ph. (951) 955-4777 Fax (951) 955-4886
Palm Desert Office 77-933 Las Montañas Rd., # 201 Palm Desert, CA 92211-4131 Ph. (760) 863-8886 Fax (760) 863-7072

HYDRANT FIRE FLOW VERIFICATION REQUEST

Permit # BR51901412
APN # 948-530-028 & -039
Address: 24885 Whitewood Rd
Murrieta, CA 92562

Office Use Only

RIVERSIDE COUNTY FIRE DEPARTMENT HAS CONDUCTED A PRELIMINARY REVIEW FOR PERMIT APPLICATION PURPOSES ONLY AND NOT FOR PERMIT ISSUANCE. ANY INFORMATION PROVIDED IS SUBJECT TO CHANGE AND IS VALID FOR 180 DAYS.

DATE: 11/18/19 BY: [Signature]

RVCID Wet Stamp Only

Please provide the permit number for the building/installation/site preparation issued by the Building and Safety Department on all plans, documents, and correspondence. Without the permit number, we cannot process the permit. The following shall be obtained from the local water purveyor and submitted to the Riverside County Fire Department for review and approval prior to any releases.

The following information shall be included on all letter(s) and map(s):

1. A map and Assessor's Parcel Number (APN) showing the location of the fire hydrant and access roadway(s) to the property.
2. Written verification from the local water district shall be required indicating the ability to provide the following:
 - a. An approved standard fire hydrant (6"x4"x2½") shall be located within 600 feet from the hydrant to the furthest portion of the building as measured along the exterior ground floor walls.
 - b. The minimum fire flow shall be 3000 gpm at 20 psi residual pressure for a 3 hour duration.
 - c. Water district must also indicate the size of the water main serving the fire hydrant.

Construction Type Square Feet 10,000 Fire Sprinklered Non-Fire Sprinklered

At the applicant's request, this form is being provided prior to the site plan/architectural review. Therefore, fire flow requirements may not be accurate, and an additional fire flow letter may be required.

Applicant's Signature

Only **original** documents will be accepted. Copies and faxes of the letter and map will not be accepted.

*Valid for 1 year



Standard Hydrant
(Wet Barrel)



Super Hydrant
(Wet Barrel)



Super Hydrant
(Dry Barrel)



Wharf Hydrant
(Wet Barrel)